



Asseverazione dei fattori di conversione in energia primaria dell'energia termica

Affidavit of conversion factors in primary thermal generation

Si dichiara che i fattori di conversione in energia primaria di:

We hereby declare that the primary energy conversion factors of:

Unità operativa:

Operative unit:

Sono stati calcolati secondo le disposizioni del Decreto Interministeriale del 26 giugno 2015 e della norma UNI EN 15316:2018:

Are been calculated in according to the provisions of Ministerial Decree of June 26, 2015 and by the standard UNI EN 15316:2018:

VI. ENERGIA SRL

VIA STRADELLA DEI NODARI 3 - 36100 VICENZA (VI)

RETE DI TELERISCALDAMENTO DI ASIAGO

CENTRALE TERMICA LOCALITÀ TURCIO, ASIAGO (VI)

Asseverazione dei fattori di conversione in energia primaria dell'energia termica calcolati secondo il metodo indicato dalla norma UNI EN 15316:2018: «Prestazione energetica degli edifici - Metodo per il calcolo delle richieste di energia e delle efficienze del sistema»

Affidavit of conversion factors in primary thermal generation calculated in according to the method indicated by standard UNI EN 15316:2018 "Energy performance of buildings – Method for calculation of system energy requirements and system efficiencies"

SONO PARI A / AMOUNTING TO

fP,nren = 0,01 fP,ren = 1,20 fP,tot = 1,21

04 | 09 | 2018

Prima emissione
First certification

03 | 09 | 2022

Emissione corrente
Current issue

Flavio Ornago

B. U. Management Systems Director